

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

October 22, 2008

DACCO INC. OF WISCONSIN DICK HARTENSTEIN 2697 HWY P RICHFIELD WI 53076 FOREST RIVER PREMIERE STRUCTURES DICK HARTENSTEIN 2501 OAKLAND AVE ELKHART IN 45517

Re: Description: PREFABRICATED PLUMBING SYSTEM

Manufacturer: FOREST RIVER PREMIERE STRUCTURES

Product Name: DACCO TRAILER
Model Number(s): DACCO #10
Product File No: 20080589

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2014.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 28 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the
 department's stamp of approval. The plans and specifications must be open to inspection by an authorized
 representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means
 concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in
 a modular building component, which will not be visible for inspection when delivered to the final site of
 installation.

This approval supersedes the approval issued on March 25, 2004 under product file number 20040166.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040166.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742 Fax: 608-267-9566

E-mail: Jerry.Thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 08058902.DOC